

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 10

Dated: 29.06.24

It is certified that an inspection team headed by Brijas Pati Yadav  
(Name of Officers with designation) from Chemist  
(Name of Department/ Office) inspected the P.H. Division, Siwan  
(Name & Address of the school) on 29.06.24 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
The above is valid for a period of 1 year

Signature with Seal: .....

Name : [Signature] 29/06/24

Designation : Assistant Engineer  
P.H. Sub-Division, Siwan

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To

New Iqra Public School

Harihans, Siwan

(Name & Address of the Institution)

[Signature]  
**MANAGER**  
**NEW IQRA PUBLIC SCHOOL**  
**HARIHANS, SIWAN-841286**

[Signature]  
**PRINCIPAL**  
**NEW IQRA PUBLIC SCHOOL**  
**SIWAN-SISWAN ROAD, HARIHANS**  
**SIWAN, BIHAR (841286)**  
**UDISE NO.-10160905517**  
**PHED/SWAN/2019-20/0244**

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



बिहार सरकार

**District Level Water Testing Laboratory:- Siwan**

Address- Kachahari Campus Pani Tanki Siwan-841226 (Bihar)

**TEST REPORT**

Name & Address of the Customer :- NEW IQRA Public School, Harihansh, Siwan.	Date:	29.06.2024
	Sample No.	-
	Sample Description	Drinking Water
	Sampling Plan & Method	IS3025(Part-1)1987(RA 2019)
	Sample Collected On	28.06.2024
	Date of Performance (s)	29.06.2024
	Ref No.	-

**Analysis Result**

Sl. No.	Test Parameter	Unit	Test Method	Result	IS 10500:2012 Amd. 1&2		Remarks
					Acceptable Limit	Permissible Limit	
1	pH at 25 °C		IS 3025 (Part 11) : 2022	6.68	6.5	8.5	
2	Turbidity	NTU	IS 3025 (Part 10) : 2023	0.9	1	5	
3	Total Dissolved Solids (TDS)	mg/l	IS 3025 (Part 16) : 2023	166	500	2000	
4	Total Hardness (as CaCO <sub>3</sub> )	mg/l	IS 3025 (Part 21) : 2009 (RA- 2019)	70.56	200	600	
5	Calcium (as Ca)	mg/l	IS 3025 (Part 40) : 1991 (RA- 2019)	17.42	75	200	
6	Magnesium (as Mg)	mg/l	IS 3025 (Part 46) : 1994 (RA- 2019)	6.65	30	100	
7	Chloride (as Cl)	mg/l	IS 3025 (Part 32) : 1988 (RA- 2019)	31.53	250	1000	
8	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	IS 3025 (Part 23) : 1986 (RA- 2019)	62.72	200	600	

29.06.2024

**MANAGER**  
NEW IQRA PUBLIC SCHOOL  
HARIHANS, SIWAN-841286

**PRINCIPAL**  
NEW IQRA PUBLIC SCHOOL  
SIWAN-SISWAN ROAD, HARIHANS  
SIWAN, BIHAR (841286)  
UDISE NO.-10160905512  
BTE/SWAN/2019-20/00244

**Authorised Signatory:-**  
**Name: - Sri Brihaspati Yadav**  
**Designation: - Chemist**

The report shall not be reproduced except in full, without approval of the laboratory.